







DUCTWORK				
A	B	C	D	QTY.
12"	12"	12"	1"	1






CURBPLATE		
WIDTH	LENG.	QTY.
18"	18"	1



FAN MODEL	A	B	C	D
28D	17½"	17½"	2"	4"



FAN MODEL	A	B	C	D	WT. LBS.
28D	26½"	20⅞"	16½"	19" SQ.	60 LBS.



*IT IS THE RESPONSIBILITY OF THE ARCHITECT/OWNER TO ENSURE THAT THE HOOD CLEARANCE FROM LIMITED-COMBUSTIBLE MATERIALS IS IN COMPLIANCE WITH LOCAL CODE REQUIREMENTS

ALL EQUIPMENT IS UL LISTED COMPONENTS

HOODMART HOODS ARE BUILT IN COMPLIANCE WITH :
NFPA #96 & UL710

AND ARE RECOGNIZED BY ONE OR MORE OF THE FOLLOWING:
- NSF INTERNATIONAL -UL

HOOD NO.	MODEL	LENGTH	MAX. COOKING TEMP.	① EXHAUST PLENUM						② SUPPLY PLENUM						HOOD CONSTRUCTION
				TOTAL EXH. CFM	RISER(S)					TOTAL SUP. CFM	RISER(S)					
					WIDTH	LENG.	QTY.	CFM	S.P.		WIDTH	LENG.	QTY..	CFM	S.P.	
1	EXSS009C 9X30	108"NOM 108"OD	700 Deg.	1800	12"	12"	1	1800	.375"	-	-	-	-	-	STAINLESS STEEL	

HOOD NO.	FILTER(S)				LIGHT(S)			UTILITY CABINET(S)					EST. HOOD WEIGHT
	TYPE	QTY.	HEIGHT	LENGTH	TYPE	QTY.	WIRE GUARD	FIRE SYSTEM		ELECTRICAL MODEL #	SWITCHES		
								TYPE	SIZE		QUANTITY	LOCATION	
1	S.S. BAFFLE W/ HANDLES	3	20"	16"	INCANDESCENT LIGHT	3	NO	--	--	--	--	--	220 LBS.
		3	20"	20"									

FAN UNIT NO.	FAN UNIT MODEL #	EXHAUST FAN									SUPPLY FAN									
		MODEL	TAG	CFM	S.P.	RPM	H.P.	Ø	VOLT	FLA	BLOWER	HOUSING	TAG	CFM	S.P.	RPM	H.P.	Ø	VOLT	FLA
1	28D EF-1	28D	EF-1	1800	.375"	1625	1/2	1	115	5.6										
2																				

REVISIONS					172 REASER COURT ELYRIA, OHIO 44035	TOLL FREE : 1-800-715-1014 FAX: 1-800-716-1214
REV	DATE	DRWN BY	APP'D BY	REMARKS		
-	-	-	-	-		
					EQUIPMENT SCHEDULE	
					CONCESSION CANOPY	
					CONTRACT NO. -	ITEM NO. -
					JOB: -	
					LOC: -	
					-	
					CUST: -	
					CUST#: -	
DATE		SCALE			DWG#11911	
-		AS NOTED				
DRAWN BY		APPROVED BY				
-		-			SHT -	
					OF -	